



Product Service

Attestation of Conformity

No. N8A 118679 0004 Rev. 00

Holder of Attestation: **TAMESOL BUILDING A GREEN FUTURE, S.L.**
AVDA. DIAGONAL NUM. 534, PLANTA ENT,
PUERTA IZQ.
08006 BARCELONA
SPAIN

Product: **Crystalline Silicon Terrestrial Photovoltaic (PV) Modules**
Mono-crystalline Silicon Photovoltaic Module

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for conformity assessment. For details see: www.tuvsud.com/ps-cert

Test report no.: 704062366201-00

Date, 2023-09-06

(Zhulin Zhang)

Page 1 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.





Product Service

Attestation of Conformity

No. N8A 118679 0004 Rev. 00

Model(s):

TM-XXXM-100BI, XXX=490 to 515 in step of 5,
 TM-XXXM-110BI, XXX=530 to 555 in step of 5,
 TM-XXXM-120BI, XXX=590 to 615 in step of 5,
 TM-XXXM-132BI, XXX=645 to 680 in step of 5,
 TM-XXXM-100HC, XXX=485 to 510 in step of 5,
 TM-XXXM-110HC, XXX=530 to 555 in step of 5,
 TM-XXXM-120HC, XXX=585 to 610 in step of 5,
 TM-XXXM-132HC, XXX=645 to 670 in step of 5,
 TM-XXXM-108HC, XXX=390 to 415 in step of 5,
 TM-XXXM-120HC, XXX=445 to 460 in step of 5,
 TM-XXXM-132HC, XXX=490 to 510 in step of 5,
 TM-XXXM-144HC, XXX=535 to 550 in step of 5,
 TM-XXXM-108AB, XXX=390 to 415 in step of 5,
 TM-XXXM-120AB, XXX=445 to 460 in step of 5,
 TM-XXXM-132AB, XXX=490 to 510 in step of 5,
 TM-XXXM-144AB, XXX=535 to 550 in step of 5,
 TOP-XXXM-108HC, XXX=410 to 435 in step of 5,
 TOP-XXXM-120HC, XXX=455 to 485 in step of 5,
 TOP-XXXM-132HC, XXX=510 to 535 in step of 5,
 TOP-XXXM-144HC, XXX=555 to 585 in step of 5,
 TOP-XXXM-108AB, XXX=410 to 435 in step of 5,
 TOP-XXXM-120AB, XXX=455 to 485 in step of 5,
 TOP-XXXM-132AB, XXX=510 to 535 in step of 5,
 TOP-XXXM-144AB, XXX=555 to 585 in step of 5
 xxx is standing for rated output power at STC

Parameters:

Construction:	Framed, with Junction box, Cable and Connectors
Test Laboratory:	Yangzhou Opto-electrical product testing institute 10 Kaifa West Rd., Yangzhou, Jiangsu, P. R. China 225009
Safety Class:	Class II
Maximum System Voltage:	1000V DC or 1500V DC
Fire Safety Class:	Class C according to UL790

Tested according to:

EN IEC 61730-1:2018
 EN IEC 61730-2:2018
 EN IEC 61730-1:2018/AC:2018-06
 EN IEC 61730-2:2018/AC:2018-06

Page 2 of 2

This Attestation does not replace the regulatory EU Declaration of Conformity (DoC) and does not allow for CE marking. After preparation of the necessary documentation and establishing compliance to requirements of all applicable directives, the manufacturer may sign a DoC and apply the CE marking. The DoC is issued under the sole responsibility of the manufacturer.

